


www.firecontrolinstruments.com

LOUDSPEAKER APPLIANCES

DESCRIPTION

FCI loudspeaker notification appliances are U.L. Listed for Emergency Fire Alarm Voice Evacuation Systems under U.L. Standard I480. The devices consist of a preassembled 4 or 8-inch speaker with fire retardant and moisture resistant cone with whizzer, 70.7 volt line transformer and line supervision capacitor installed on a U.L. Listed square or round grille.

A variety of U.L. Listed enclosures is also available and must be used with the appropriate speaker/transformer/ grille package in order to comply with U.L. Listing requirements. The superior performance and high quality of these speaker assemblies allow their use, when permitted, as background music reproducers in addition to emergency use.



SPECIFICATIONS

SPEAKER

Ceramic magnet
Frequency response
Output (1 Watt input)
Voice coil (8 ohm)

UDT

5 oz.
400 Hz - 4kHz.
94 dB @ 1 mtr
¾-inch diameter

UHT

10 oz.
50 Hz - 15 kHz.
95 dB @ 1 mtr
1-inch diameter



TRANSFORMER

Primary volts
Power rating (multi-tap)
Insertion loss
Terminations

70.7Vrms
¼, ½ & 1Watt
1.5 dB
6" color-coded

70.7Vrms
½, 1, 2 & 5Watt multi-tap
1.5 dB
6" color-coded

ORDERING INFORMATION

SPEAKER

Part No.	Model	Size/Shape	Finish	Required Enclosure
136-48931	UDT7C-B-U52-4	4" dia. round, flush	White enamel	See Fig. 1
136-48831	UDT7C-B-U162-4	4" square, flush	White enamel	See Fig. 1
136-50931	UHT70C-U51-8	8" dia. round	White enamel	U95-8
136-50831	UHT70C-U161-8	8" square	White enamel	USE175-4

ENCLOSURES

Part No.	Model	Description	Size
136-98902	U95-8	Recessed round enclosure	11 ¾ dia. x 4 ¼ inches deep
136-99830	USE175-4	Surface square enclosure	11 ⅝ x 11 ⅝ x 4 inches deep

An ISO 9001 Company

Specifications are provided for information only, are not intended to be used for installation purposes and are believed to be accurate. However, no responsibility is assumed by Fire Control Instruments for their use. Specifications subject to change without notice.
© 2003 All Rights Reserved




Figure 1

NOTE: All boxes must be recessed in wall

Flush Mount (Figure 1)

Item No	Description/Model
1	UDT7C-B-U52-4 UDT7C-B-U162-4
2	Std. 4-inch square x 1 ½-inch deep electrical box
3	Std. 4-inch square x 1 ½-inch deep electrical box

Specifications are provided for information only, are not intended to be used for installation purposes and are believed to be accurate. However, no responsibility is assumed by Fire Control Instruments for their use. Specifications subject to change without notice.

© 2003 All Rights Reserved